

## 水 務 署 Water Supplies Department

總部 Headquarters 香港灣仔告士打道七號入境事務大樓 48 樓 48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號

Our ref. 來函檔號

Your ref.

(6) in WSD 3321/2021 T/J(1411/2021)

電話

Tel.

傳真 Fax.

2824 0578

28 December 2021

Welson Metal & Sanitary Ware MFY. Blk F, 18/F & Blk G&H, 19/F, Phase 1, Superluck Industrial Center, 45-53 Sha Tsui Road, Tsuen Wan, N.T., Hong Kong

(Attn.: Mr Ken MA)

Dear Sir,

## Approval of "WELSON" Float Operated Valves (General Acceptance No. C20211447)

Your letters ref. WEL-2002-31082021AP, WEL-2002-29092021AP-C1 and WEL-2002-08122021AP dated 31 August 2021, 29 September 2021 and 8 December 2021 respectively refer.

Having considered the test report ref. 213345PC210221A issued on 6 December 2021 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

FS Welson Metal Manufacturing Company Limited

**Country of Origin:** 

the Mainland of China

Brand:

Welson

**Details of Fitting:** 

Copper alloy float operated valve

Model and Size:

2002-50T - 50mm 2002-80T - 80mm 2002-100T - 100mm

2002-150F - 150mm





**Body Markings:** 

WELSON size in inch

**Expiry Date:** 

19 August 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG) for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue

ME/MC ] - with soft copy only